



September 16, 2009

**Addendum No. 001
9-090922**

To: Plans and Specifications Holders List for:

Missouri Department of Transportation –
DISTRICT-8, Two New Truck Wash Buildings, Buffalo & Seymour, MO

Anchor Bolts

Column base plates with anchor bolt size and lengths to be determined by Building Manufacturer. Adhere anchor bolts with Red Head Brand - A7 Adhesive or equal. It is a fast dispensing, fast curing acrylic resin and hardening agent.

Columns

Use uniform depth.

Metal Building Code Requirements

Building Code – 2003 IBC

Temporary Power

Temporary 30-amp service provided by MoDOT.

Existing Concrete Foundation Details

See Attached two sheets. Field verify at each site the exact pier dimensions at foundation wall.

Note for Passage Doors

At both the Buffalo & Seymour site each foundation has only one door into the Equipment Room entering from the Wash Room. Field verify. Thus, each site has three (3) fiberglass/plastic composite passage doors in this Contract. Provide door hardware as required in specifications for each door.