



9-100115M  
Addendum No. 001

January 4, 2010

To: Plans and Specifications Holders List for:

**DISTRICT – 6  
TIME AND MATERIAL  
PROJECT AND SERVICE CALL MECHANICAL SERVICES  
VARIOUS ST. LOUIS AREA DISTRICT MISSOURI LOCATIONS**

MoDOT must maintain certain pieces of MHTC owned unique equipment that we have that at various locations. In order to properly maintain such critical equipment, certified and/or qualified technicians are necessary. This does not include basic HVAC equipment such as 3 to 7 ton HVAC units, PTAC's, unit heaters, split systems, radiant tube heaters, and small wall units that exist throught the district at project offices, scales, maintenance buildings, and Welcome Centers.

The special equipment may include but may not be limited the locations and specialized equipment below.

**Traffic Center (TMC) 24/7 Operation. Location - 14301 South Outer Forty Dr. Chesterfield Mo. 63017-5712**

- 6 - Liebert down flow units with chilled water that require certified liebert technicians to maintain.
- 2 - Trane Intellipak RTU's with gas preheat for 30 to 50 Ton capacity interfaced with "Andover Controls"
- 2 - Carrier Chillers to support the Liebert Units
- 1 - Lochinvar Gas boiler
- 1 - 300 KVA "Generac" diesel back up generator (Annual load testing and PM)

**District Office Location - 1590 Woodlake Dr. Chesterfield Mo. 63017-5712)**

- 1 - Liebert down flow unit that require certified Liebert technicians to maintain
- 4 - Trane Intellipak RTU's ranging on sizes form 30 to 50 Ton capacity interfaced with "Andover Controls"
- 1 - Barsch Electric Boiler interfaced with "Andover Controls"

**General Service Facility Location - 2309 Barrett Station Rd, Ballwin Mo. 63011 Bldg 2309**

- 2 - Lochinvar Gas boilers for in floor radiant heat system
- 1 - Carrier "Pilot" Energy Management System for office HVAC area.

The requirement to protect and maintain our investment in the MHTC's special systems may require additional multiple award price agreements as deemed necessary at the MHTC's sole discretion.

-END SECTION-