

Missouri
Department
of Transportation



105 West Capitol Avenue
P.O. Box 270
Jefferson City, MO 65102
(573) 751-2551
Fax (573) 751-6555
www.modot.org

Pete K. Rahn, Director



2007 Missouri Quality Award Winner

February 2, 2010

**Addendum No. 3
9-100205**

To: Plans and Specifications Holders List for:

Missouri Department of Transportation – DISTRICT-2, Marshall Project Office & Maintenance Building – Marshall, MO

Soils Report

The footings for the Project Office and the Maintenance Building have been engineered. Use the Concrete Footing Schedule in the Construction Documents in lieu of the soils report. Note "P" on Site Plan (Sheet 1 of 18) still holds true for the Maintenance Building and Project Office.

In the Drawings

Sheet 8 of 30:

Door Schedule, Door 11 is a solid core pine raised panel bi-fold door. Stain and varnish. See Section 09900 Painting.

Sheet 16 of 30:

The VCT in 103 Hall is to be outside of the systems furniture with carpet under the systems furniture.

Sheet 13 and 19 of 30:

Wall Type 'D', change out one layer of 5/8" Type 'X' gypsum board to 5/8" OSB on the 104 Break Room and 105 Work Area side. Continue upwards with a laminate of 5/8" OSB and 5/8" Type 'X' gypsum board on truss directly above same wall in attic space.