

ADDENDUM 001 Request for Bid HVAC MATERIALS RFQ 9-160316KHH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **March 16, 2016 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature (Signature of person authorized to sign)	Department of Transportation <i>Kristi Hixson</i> (Authorizing Signature)
Date Signed:	Date Signed:3/14/2016

HVAC Materials must meet the following HVAC schedule/specification:

HVAC SCHEDULE						
SYM.	UNIT	MANUFACTURER	BTU OUTPUT	FUEL	VOLTAGE	REMARKS
A	36" X 36" SHUTTER MOUNT EXHAUST FAN W/WEATHERHOOD	DAYTON 1HLB6 & 1WBW2 OR EQUAL 6.4 AMPS	6,480 CFM	ELECTRIC	120	COMMERCIAL TYPE BELT DRIVE WALL EXHAUST FAN INCLUDING OSHA GUARD AND SHUTTER.
B	MOTORIZED DAMPER WITH WEATHERHOOD	DAYTON MODEL 3C728 & 1WBW1 OR EQUAL .37 AMPS	--	ELECTRIC	115	30" MEDIUM GRADE, MOTORIZED, GALVANIZED STEEL DAMPER WITH 1HP MOTOR. WIRE TO OPEN WHEN EXHAUST FAN IS TURNED ON.
C	GAS FIRED UNIT HEATER	REZNOR MODEL UDAP 200 OR EQUAL	166,000	PROPANE	115	SINGLE BURNER COMBUSTION, 4.6 AMPS, DITECT SPARK IGNITION, 100% LOCK-OUT & CL-1 STANDARD HEATING ONLY THERMOSTAT.
D	CARBON MONOXIDE EXHAUST SYSTEM	CAR-MON MODELS SERIES BA AND CMW-9 OR EQUAL	--	ELECTRIC	115	INCLUDE HOSE, BALANCER, DUCTING, EXTERIOR WALL HOOD AND FLANGE MOUNTED EXHAUST FAN, 3/4 HP MOTOR, 13.8 AMPS.
E	PTAC UNIT	FRIEDRICH MODEL PDH07K OR EQUAL	COOL 6.3K HEAT 7.7K	ELECTRIC	208/230	EER 12. INCLUDE PDXWSA WALL SLEEVE, PDXDEA LATERAL DUCT KIT & PXGA EXTERIOR GRILL.

