

Question: Where does the sewer line get capped off?

Answer: The sewer line needs to be capped off from the inside of the holding tank or pit after the bottom has been punctured and before the sand is placed or if collapsing the walls, cap just outside the existing concrete.

Question: Where does the water line get capped off?

Answer: The water line needs to be capped off at the yard hydrant.

Question: Who is responsible for the telephone box/pedestal?

Answer: The contractor will need to work with the telephone company to disconnect wiring at closest point of telephone box/pedestal. The telephone box/pedestal needs to be removed and abandon wire in place.

Question: If we wish to FEDEX our bid in, which address and to whose attention should we FEDEX the bid to?

Answer: The physical address to send bids via FEDEX is General Services Procurement, 830 MoDOT Drive, Jefferson City, MO 65109, please make attention Kristi Hixson. Bids must be received by 2:00 p.m., Central Time, June 3, 2015. See information on page 1, Notice to Bidders, of the bid document.

Question: Is the project considered Building Construction or Heavy Highway?

Answer: This project is considered Building Construction.

Question: Will certified payroll be required.

Answer: Yes.

Question: Will questions from pre-bid meeting be provided?

Answer: A pre-bid meeting was not held for this project. We did schedule time on May 27th for anyone interested in visiting the site.