

Missouri Department of Transportation  
Roberta Broeker, Interim Director

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

## ADDENDUM 001 Request for Bid Salt Dome Roof Replacements Project RFB 9-150609KH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **June 9, 2015 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature   (Signature of person authorized to sign)	Department of Transportation  <i>Kristi Hixson</i>  (Authorizing Signature)
Date Signed:	Date Signed:5/29/2015

**Question:** Will CertainTeed Landmark shingles be an acceptable product?

**Answer:** Yes, as long as they are manufactured at the 240 LBS per square specifications.

**Question:** Division 7 mentions 30 lb plain felt and synthetic underlayment. Which product is to be installed?

**Answer:** Synthetic underlayment is required in place of 30 LBS felt as outlined in the specification.



**Question:** Section 01500 describes requirements for field offices. We would have no need for a field office on these projects. Will we be required to provide accommodations for Architect, etc?

**Answer:** Providing a field office for this project is not required.