

ADDENDUM 001 Request for Bid Lightning Surge Arrestors and Grounding for GPS Antennas RFB 9-160720KH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **July 20, 2016 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature <hr/>	Department of Transportation <i>Kristi Hixson</i> <hr/>
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: 7/12/2016

Questions:

Question: Mark 5 of the drawing shows a receptacle and calls out a Square D device which does not have a receptacle. Is this to show it is AC power? Or is there a surge protection plug strip included here?

Answer: The drawing and reference note 5 calls for the contractor to provide a surface mounted box with simplex receptacle. The AC surge suppressor (Item D) mounts to the box and protects the simplex receptacle. The receptacle is supplied by an existing UPS via new cord and plug per reference notes 6 & 7.

