

Missouri Department of Transportation  
Roberta Broeker, Interim Director

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

## ADDENDUM 002 Request for Bid Fruitland Demolition and Vault Toilet Installation Project RFB 9-150603KH

Bidders should acknowledge receipt of Addendum 002 (TWO) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **June 3, 2015 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature   (Signature of person authorized to sign)	Department of Transportation  <i>Kristi Hixson</i>  (Authorizing Signature)
Date Signed:	Date Signed:6/1/2015

**Plan Sheet A-1:** New 3'x4'x4" concrete pad **change** to New 3'x3'x4" concrete pad as identified in the Scope of Work section under Additional Work & Project Information.

**Question:** Scope of Work, Vault Restroom Unit section: Backfill and preparation shall be completed in the same manner, drainage will flow away from the structure. Sidewalk leading to vault and curb ramp leading from the truck parking area shall be constructed according to ADA standards.  
Question: Is the contractor responsible for installing the sidewalk and curb ramp?

**Answer:** The contractor is responsible for installing the sidewalk leading to vault and curb ramp leading from the truck parking area in accordance to ADA Standards.

