

ADDENDUM 002 Request for Bid Barrett Station Truck Wash RFB 9-160412KH

Bidders should acknowledge receipt of Addendum 002 (TWO) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **April 12, 2016 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature _____ (Signature of person authorized to sign)	Department of Transportation <i>Kristi Hixson</i> _____ (Authorizing Signature)
Date Signed:	Date Signed:4/8/2016

Question: Is the contractor responsible for the pit drain, concrete pad, pipe bollards in approach slab, and drainage pipe and roof drains?

Answer: Frame and grate for pit drain to be provided by MoDOT. Contractor will be required to inset grate frame into the pit wall. Contractor to coordinate with MoDOT to install drain pipe for pit.

MoDOT is responsible for the concrete pad, pipe bollards in approach slab, draining pipe and drains.

Question: Does the contractor just leave an opening for the doors? Are the doors provided and installed by MoDOT?

Answer: Yes, contractor will leave an opening for the doors. MoDOT will provide and install the doors.

Question: Are there any underground utilities that will need to be exposed?

Answer: No.

