

ADDENDUM 003 Request for Bid Fulton Wash Bay Enclosure Project RFB 9-161115KH1

Bidders should acknowledge receipt of Addendum 003 (THREE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **November 15, 2016 2:00 PM Central Time**.

Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature <hr/> (Signature of person authorized to sign)	Department of Transportation <i>Kristi Hixson</i> <hr/> (Authorizing Signature)
Date Signed:	Date Signed: 11/9/2016

Clarification to Addendum #1 regarding the gas line:

Gas Line: MoDOT to coordinate with gas company to run a new service up to southern sidewall near southeast corner of existing wash bay. Prior to installing the tube heater and its gas line, contractor shall verify with MoDOT where gas line will be stubbed out of side wall. Contractor to notify MoDOT 72 hours prior to needing the service line tied into the contractor provided gas line. The gas line feeding building up to meter will be ½ in or greater.

Water Line:

The water service entrance line is 2 inches.



