

ADDENDUM 003 Request for Bid Milan Mechanics Building RFB 9-161201KH

Bidders should acknowledge receipt of Addendum 003 (THREE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **December 1, 2016 2:00 PM Central Time.** Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature (Signature of person authorized to sign)	Department of Transportation <i>Kristi Hixson</i> (Authorizing Signature)
Date Signed:	Date Signed: 11/28/2016

In accordance with the boring report, the soil beneath the base material consists of high plasticity clay. To ensure proper compaction, the contractor shall over-dig 1 foot below foundation footing and place 1" +/- clean rock compacted.

As noted throughout the bid document, MoDOT is furnishing the pre-engineered metal building package for this project.

