

beyond the wye and cap for connection by others. Actual location of service line to be adjusted as required, in coordination with MoDOT.

Plan Sheet 6 – At double cleanout, shown on detail, backfill under the concrete collar shall be granular backfill material, as required in specification Section 02220, Paragraph 2.4.

GENERAL CLARIFICATIONS

1. Pipe embedment material shall be as required in specification Section 02220, Paragraph 2.2.A. Pipe embedment shall be completed as required in specification Section 02220, Paragraph 3.6.C. Minimum depth of granular fill below the pipe shall be four (4) inches.
2. A City of Versailles Excavation permit shall be obtained by contractor. The deposit will be returned after cleanup and restoration is approved by the City. Contact the City for permit requirements and fees.
3. In lieu of open cut excavation, sewer may be installed by boring under street and driveway. At street crossing, steel casing of at least 1/4" thickness shall be provided and installed if boring method is used. No additional payment will be made for boring or casing.
4. Signs, as shown in NAME PLATE DETAIL on plan sheet 6 shall be placed at manholes and at entrance driveway. There shall be three (3) signs in all.
5. All areas of construction activity shall be restored to a condition that is equal to, or better than, the conditions prior to construction, as required by specification Section 01000, Paragraph 14.
6. All erosion control measures shall be installed, maintained and removed by contractor.
7. All 6" and 4" sewer pipe shall conform to Standard Dimension Ratio 26 (SDR 26), as shown in specification Section 02730, Paragraph 2.1.B.1 on page 02730-5.

VENDOR QUESTIONS

Question: Do you require \$3,000,000.00 of insurance for this project?

Response: Yes, as specified in the special terms and conditions.

Question: Is this project tax exempt?

Response: Yes, as specified in the special terms and conditions.

Question: How many lineal feet of MoDOT driveway has to be filled with full depth chat backfill?

Response: Plan Sheet 5 – The MoDOT driveway and parking area must be backfilled as shown by the Aggregate Surface Area detail. The aggregate surface area begins near the cleanout on the service line at Station 21+83, as shown on the plan view of the sewer alignment on Plan Sheet 3. Specification Section 02220, Paragraph 3.8.A. states “All areas disturbed by construction operations shall be restored by paving, gravel surfacing, seeding, or sodding as indicated on the Drawings and specified.”

Question: Is there any rock that will need to be dealt with to put this sewer line in?

Response: No exploratory borings were completed for this project.

Question: Has there been a core sample of the area that this new line will be placed?

Response: No.

Question: Is there a rock clause to deal with any rock that may need to be excavated?

Response: Specification Section 02220, Paragraph 3.2 states:
“No classification of excavated materials, regardless of type or condition, will be made for purposes of payment. All excavation shall be unclassified. Excavation and trenching work shall include the handling and removal of all materials, regardless of its nature, excavated or removed from the site in performance of the Work. No separate payment will be made for rock.”