

- D. All exterior wiring shall be in galvanized Rigid Steel Conduit.
- E. Type MC cable with grounding conductor or type AC cable may be used for **6 foot** fixture whips.

Question: What is the estimate for this project?

Answer: The range for the cost of this project is \$50,000 - \$100,000.

Question: When do you anticipate this project beginning?

Answer: It is anticipated the notice to proceed will be approximately 30 days after bid opening.

Question: The 3-Ceiling Cassettes for HVAC the print shows they have wireless stats, but do they need control wire to outdoor HP unit or power to each ceiling cassette?

Answer: The electrical power for the 2' x 2' cassettes is from the exterior heat pump unit. These units need power but extra circuits are not needed. The mechanical contractor is responsible for that power connection.

Question: Can MC cable be used inside sheetrock walls?

Answer: See specification 16108 above.