



June 26, 2009

**Addendum No. 001  
9-090721**

To: Plans and Specifications Holders List for:

**District-2, Overhead Door Replacements, Two North Central Locations**

The bid opening date and time remains unchanged.

Corrections include:

- The Macon Weld Shop shall not require an opener.
- No openers will be reused.
- A total of two openers are to be supplied and installed at the Macon Special Crews – Bridge Building.
- Openers power shall use existing 230V single phase.

Time for completion is here by changed. The contractor shall complete the project within 60 working days after receipt of Notice to Proceed.

Omit all references to coiling doors, as no coiling doors are required.

- END SECTION -