

Missouri
Department
of Transportation



105 West Capitol Avenue
P.O. Box 270
Jefferson City, MO 65102
(573) 751-2551
Fax (573) 751-6555
www.modot.org

Kevin Keith, Director

June 2, 2011

**Addendum No. 001
IFB 9-110613**

**MISSOURI DEPARTMENT OF TRANSPORTATION: DISTRICT – 5, REST AREA –
EASTBOUND, INTERSTATE I-70, BOONVILLE, MISSOURI**

BID OPENING DATE AND TIME: JUNE 13, 2011 AT 3:00 P.M. LOCAL TIME.

At the contractor's discretion, three phase pumps may be supplied with VFD's for converting the incoming single phase power to three phase.

ABS, Myers, and Gormann Rupp are acceptable pump manufacturers in addition to Flygt.

Contractor must give 24 hour notice for service disruptions.

The gravel drive on sheet 7 may be open cut and must be backfilled with full depth granular backfill.

The asphalt pavement cut shall be patched with 6" asphalt or early strength concrete and full depth granular backfill.

The 2" force main shall have a 42" bury depth. No granular bedding is required.

Delete paragraph 3.9.c on page 02732-11 of the specifications.

Delete the cleanout to be removed at the NE corner of the rest area building.

END SECTION