



August 13, 2009

To: Plans and Specifications Holders List for:

Addendum No. 004
9-090813A

DISTRICT – 2, Brick Building Restoration, Macon, Missouri

Bid opening date and time: August 19, 2009 at 3:00 PM.

The following request for information contractor questions and the engineer's answers are incorporated as an addendum for all potential bidders to consider for their bids.

RFI from Darien Henderson & Marilyn, Building Restoration Corp.

1. In reference to:
 4. EXAMINATION OF DOCUMENTS AND SITE OF WORK
 - I. Accompanying the proposal is the Bidder's Statement of Qualifications. Failure of bidder to submit the Bidder's Statement of Qualifications with the bid will void the bid. The owner does not maintain Bidder's Statement of Qualifications on file. The question was do they provide the above mentioned qualification request.

Please disregard the section 4. EXAMINATION OF DOCUMENTS AND SITE OF WORK in its entirety.

2. The question was asked if the forms on pages 9 and 10 need to be completed, since they are not addressed in the bidder checklist.

Yes, these forms do need to be completed.

3. As I am completing my bid on this project it has come to my attention that the only place that I have found that the entire building (1939) get 100% tuck pointed is from my notes at the pre bid. The specs read like its a spot tuck pointing job and from past experience if there is not something in writing stating that its a 100% tuck pointing job then you will have bids that is extremely different.

All brick surfaces on the '1939 Building' are to be cleaned, repaired, repointed and sealed per the plans and specifications. The estimated square footage for this portion of the work is 3900. The 1969 addition brick veneer will be cleaned and sealed per the plans and specifications.

- END SECTION -