

**Missouri Department of Transportation**  
*David B. Nichols, Director*

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

**ADDENDUM 001**  
**Alton Maintenance Building Restroom Renovation Project**  
**Request for Bid 9-140514TV1**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing and including it** with the original bid. The due date for receipt of bids remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Name: Tom Veasman Title: Sr. General Services Specialist
Bidder Signature	Department of Transportation  
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: May 7, 2014

Alton Specifications:

The Alton Maintenance Building Restroom Renovation Specifications was posted to MoDOT's website on April 28, 2014.

Clarifications from Pre-Bid Conference:

- Add new 3" vent for new restroom construction.
- Remove 8' X 2' existing ductwork/vents under mezzanine between existing offices.
- Patch wall/ceiling to match existing.



*Our mission is to provide a world-class transportation experience that delights our customers and promotes a prosperous Missouri.*

www.modot.org