


Missouri Department of Transportation
David B. Nichols, Director

573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)

ADDENDUM 003
Bolivar Maintenance Building
Request for Bid 9-130426TV

Bidders should acknowledge receipt of Addendum 003 (THREE) by **signing and including it** with the original bid. The due date for receipt of bids was extended to **May 3, 2013** at 2:00PM Local Time. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name: Tom Veasman Title: Sr. General Services Specialist
Contractor/Bidder Signature <hr/> (Signature of person authorized to sign)	Department of Transportation  <hr/> (Authorizing Signature)
Date Signed:	Date Signed: April 26, 2013

Vendor Questions:

Question: Specifications 08111 - Standard steel doors (Section 2.2, D.) and 08112 – Standard steel frames (Section 2.3, F.) call for the doors to have a special profile to receive recessed weather stripping, but the hardware schedule calls for surface applied weather stripping. Please specify.

Answer: Specifications 08111 and 08112 should specify surface applied weather stripping instead of recessed weather stripping.

