

Missouri Department of Transportation  
*David B. Nichols, Director*

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

**ADDENDUM 001  
KCDC Maintenance Services Project  
Request for Bid 9-130927TV**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing and including it** with the original bid. The due date for receipt of bids remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Name: Tom Veasman Title: Sr. General Services Specialist
Contractor/Bidder Signature  (Signature of person authorized to sign)	Department of Transportation   (Authorizing Signature)
Date Signed:	Date Signed: September 23, 2013

**VENDOR QUESTIONS & GENERAL CLARIFICATIONS:**

Can the current monitoring system of the cooling/UPS systems at the Kansas City Data Center be modified to notify the awarded vendor when there is an issue? YES.

Will this meet the required monitoring requirements in the RFB? YES.

Will the use of this monitoring system cost the vendor? NO.

Can MoDOT provide an in-line diagram of the as-built KCDC facility? YES. KCDC Construction Plans are included as a separate document.

Does this contract include replacement of the UPS batteries as needed? YES.  
When were they replaced last and by whom? June/2013 by Schneider.



*Our mission is to provide a world-class transportation experience that delights our customers and promotes a prosperous Missouri.*

www.modot.org

## **KCDC Maintenance Services Project Vendor Questions Continued:**

Where are the wage rates in the Request for Bid document? The Jackson County Wage Order is provided as a separate attachment to the RFB as prevailing wages may apply.

Is this a full service contract? YES. The contract includes service and repair on all cooling and UPS components as needed.

Do the services apply to the compressors? YES.

Can a vendor that offers only cooling services or only UPS services join with another vendor to offer service on both cooling and UPS? YES. But whichever vendor that submits the bid will be held accountable for the entire contract.

Does this cooling/UPS maintenance contract include service to the transformers mounted close to the ceiling in the corner next to the CAT boxes? NO. They are not included in this contract.

Who originally provided the cooling/UPS equipment for the construction of the KCDC Facility? APC through World Wide Technology.

If additional vendor walk-throughs are needed, an appointment can be made by calling Tom Veasman at 573-522-4404.