

Missouri Department of Transportation
David B. Nichols, Director

573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)

**ADDENDUM 001
NW District Back-up Generator
Request for Bid 9-150311TV**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing** and **including it** with the original bid. The due date for receipt of bids remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name: Tom Veasman Title: Sr. General Services Specialist
Bidder Signature	Department of Transportation 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: February 26, 2015

2-25-15 Pre-Bid Meeting Discussion Items:

1. Any costs assessed by the utility (KCPL or Missouri Gas Energy) for outages or callouts related to this project will be borne by the contractor.
2. The contractor may run new conduits to the District Office building instead of using existing conduits, if it is more cost effective. However, any disturbance to the parking lot must be saw cut at least two feet wide and filled with concrete to top of asphalt. Parking lot disturbed area needs to be covered with metal plates to allow traffic flow if trench left open or to allow concrete curing.



*Our mission is to provide a world-class transportation experience that
delights our customers and promotes a prosperous Missouri.*

www.modot.org