

Missouri Department of Transportation

David B. Nichols, Director

573.751.2551

Fax: 573.751.6555

1.888.ASK MODOT (275.6636)

ADDENDUM 001 MoDOT Salt Domes Reroof Request for Bid 9-130507TV

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing** and **including it** with the original bid. The due date for receipt of bids remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name: Tom Veasman Title: Sr. General Services Specialist
Contractor/Bidder Signature	Department of Transportation 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: April 25, 2013

Vendor Question:

Please confirm the treatment of the concrete walls.

Answer:

Overlap SPF and roof coating at least 6" down from the bottom of the shingled portion and leave the remaining portion of the concrete wall as is.



Our mission is to provide a world-class transportation experience that delights our customers and promotes a prosperous Missouri.

www.modot.org