



Ed Hassinger, District Engineer

**ADDENDUM 001  
REQUEST FOR QUOTATION  
SL13-029-R7 Overhead Garage Doors**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original bid. The due date for receipt of this bid **does not change** by this Addendum. Accordingly, the following clarifications, additions/deletions, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Stephanie Austin Rashid Sr. General Services Technician
Bidder Signature	Department of Transportation  <i>Stephanie Austin Rashid</i> Authorizing Signature
Signature of person authorized to sign	Authorizing Signature
Date Signed:	Date Signed: August 21, 2012

**ADDITION TO SPECIFICATIONS**

- Contractor to remove complete steel jambs and haul away.
- Contractor to furnish and install 12 – 9” x 16’, 16 gauge steel jambs. Must include remounting steel door track angle onto new door jamb.

If this will be an additional cost, please list below:

Quantity	U/M	DESCRIPTION (including, size, and/or part #'s)	UNIT PRICE	UNIT PRICE EXTENSION	DELIVERY TIME
12	Each	Door Jams and Installation per above Specifications			

**THIS PAGE MUST BE SIGNED AND RETURNED WITH ORIGINAL RFQ.**