



Ed Hassinger, District Engineer

**ADDENDUM 001
REQUEST FOR QUOTE (RFQ)
SI12-011- RB CMP**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original quote. The due date for receipt of this Quote **does not change** by this Addendum. Accordingly, the following clarifications, additions/deletions, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Athena L. Nance Sr. Procurement Agent
Bidder Signature	Department of Transportation <i>Athena L. Nance</i>
<input type="text" value="Signature of person authorized to sign"/>	<input type="text" value="Authorizing Signature"/>
Date Signed:	Date Signed: July 12, 2011

QUESTION and CLARIFICATION

Question:

Please specify, if by coated aluminum cmp pipe, does that mean galvanized, aluminized, or polemized, or other?

Answer:

MoDOT Class B means aluminized metallic coating 14 gauge 3x1, 2 section pipes 30' each (total 60' long) with 1 band /bolts connection with a 72" pipe diameter.

Clarification:

Delivery **will be a factor in award** since material must be delivered on- site Wentzville, MO in time for MoDOT start of project.

THIS PAGE MUST BE SIGNED AND RETURNED WITH ORIGINAL RFQ.