ADDENDUM 001
REQUEST FOR QUOTE
Parking Lot Seal Coating
RFQ# SW-12-015CS

Bidders/Offerors shall acknowledge receipt of Addendum 001 (ONE) by signing and mailto: Christina.Stephens@modot.mo.gov including it with the original quote. The due date for receipt of quotes remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders/Offerors. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Chris Stephens Intermediate Procurement Agent
Bidder/Offeror Signature _____ (Signature of person authorized to sign)	Department of Transportation Chris Stephens (Authorizing Signature)
Date Signed:	Date Signed: **12/13/11**

QUESTIONS/CLARIFICATIONS

RFQ Statement: All pipe is required to be 16 gauge.

Comment: The 16 gauge is required for the smaller culvert pipe, please increase to a 12 gauge for the larger pipe or when appropriate.

When in doubt the MGS-91-11G supersedes the written instructions.

Please sign and date this addendum and return with your quote.