

**ADDENDUM 003
REQUEST FOR BIDS
RFQ NUMBER: D9091159RY**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original proposal. The due date for receipt of quote remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Gloria Perkins D9 Procurement
Contractor/Offeror Signature _____ (Signature of person authorized to sign)	Department of Transportation <i>Gloria Perkins</i> _____ (Authorizing Signature)
Date Signed:	Date Signed: 1-5-09

Question: Do you need a Grade 8 bolt? A325 Structural Bolt is a Grade 5. The A490 Structural Bolt is a Grade 8.

Response: Yes, it is imperative to have a Grade 8 Structural bolt, nut and washer as these will be used in the bridge structure. Please quote accordingly.